

MEDICAIR TEST REPORT

SCOPE OF WORK

VOC Reduction by FOZKYGB-04

REPORT NUMBER

104675897GRR-001

ISSUE DATE


27-December-2021

PAGES

9

DOCUMENT CONTROL NUMBER

Per GFT-OP-10 (6-March-2017) © 2021 INTERTEK





4700 Broadmoor Ave SE, Suite 200 Kentwood, MI 49512

Telephone: +1 616 656 7401

www.intertek.com

DRAFT TEST REPORT FOR MEDICAIR DENTAIR LTD

Report No.: 104675897GRR-001

Date: 27-December-2021

P.O.: N/A

SECTION 1

CLIENT INFORMATION

Attention: Graham Thomas MedicAir Dentair Ltd

The Barns, Hilltop Farm Lyne Lane

Chertsey KT16 0AW GBR

Phone: (+44) 01932 553023

Email: graham@medicairhealth.co.uk

Taylor Gebben Project Engineer Jesse Ondersma Project Reviewer

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Date: 27-December-2021 P.O.: N/A

Report No.: 104675897GRR-001

SECTION 2

SUMMARY AND CONCLUSION

Date Received: 10-November-2021
Dates Tested: 13-December-2021

DESCRIPTION OF SAMPLES

Part Name: FOZKYGB-04

Model Number: Not Specified

Materials Submitted: One (1) Unit

Condition of Samples: Not Specified

Shipping Condition: Good Condition

WORK REQUESTED/APPLICABLE DOCUMENTS

VOC Reduction Testing: ISO 16000-3, ISO 16000-6 Referencing NRCC-54013

Intertek Quote: Qu-01163855-5

SAMPLE DISPOSITION

At the completion of testing, samples were returned to MedicAir Dentair LTD.

Date: 27-December-2021 P.O.: N/A

SECTION 3

ISO 16000-3, ISO 16000-6 REFERENCING NRCC-54013

Date Received: 10-November-2021 Dates Tested: 13-December-2021

DESCRIPTION OF SAMPLES:

Part Name: FOZKYGB-04

Model Number: Not Specified

Materials Submitted: One (1) Unit

Condition of Samples: Not Specified

Shipping Condition: Good Condition

TEST PROCEDURE:

Testing was performed referencing NRCC-54013 (April 2011): Method for Testing Portable Air Cleaners sections 3.2 and 5.1.2.

Report No.: 104675897GRR-001

Natural system decay for the challenge chemicals is performed prior to the test. The unit was placed in the center of a chamber which was sealed and flushed with clean air for a minimum of one night. An additional enclosure fan was operated to ensure air mixing. The challenge chemical formaldehyde was injected and allowed to circulate for 15 minutes during which an air sample was taken. The system was then turned on using the highest fan speed beginning the test timing.

VOC samples were collected at 5, 10, 15, 20, 25, 30, 45, 60, 90, 120, 180, and 240 minutes after starting the system. Samples analyzed for formaldehyde were collected on cartridges treated with 2,4-dinitrophenylhydrazine (DNPH) and were analyzed using high performance liquid chromatography, HPLC. Individual VOCs were calculated using calibration curves based on pure standards.

TEST NOTES OR DEVIATIONS:

Testing performed without deviation unless noted below.

Date: 27-December-2021

Report No.: 104675897GRR-001

P.O.: N/A

TEST PARAMETERS:

Table 1: Chamber Conditions During Test Period

PARAMETER		SYMBOL	VALUE	UNITS
Chamber Volume		V	30	m ³
Testing Duration		t	4	h
Test Conditions	Average Temperature (Range)	Т	22.8 (22.2-24.1)	°C
	Average Humidity (Range)	RH	50.4 (40.6-55.9)	% RH

Table 2: Concentration of challenge chemical decay through test.

Time (min)	Formaldehyde (μg/m³)
0	259
5	159
10	124
15	93.2
20	80.3
25	57.7
30	46.5
45	30.9
60	17.5
90	11.3
120	7.6
180	8.3
240	2.4

Date: 27-December-2021

Report No.: 104675897GRR-001

P.O.: N/A




Figure 1: Concentration change throughout test for challenge chemicals




Figure 2: Removal rate of challenge chemicals.

Date: 27-December-2021 P.O.: N/A

The clean air delivery rate (CADR) is calculated according to equation 1:

$$ln\left(\frac{C_t}{C_0}\right) = -\left(k_n + \frac{CADR}{V}\right)t$$
 Eq. 1

Report No.: 104675897GRR-001

where:

 C_t : chemical concentration at time t (µg/m³) C_0 : chemical concentration at time t_0 (µg/m³)

V: volume of the test chamber (m³)

t: time (h)

CADR: Clean Air Delivery Rate (m³/h)

 k_n : constant obtained from the blank test. $k_n = 0$ if no adsorption/leaks are present.

Table 3: Purifier efficiency – calculation of clean air delivery rate and single pass efficiency.

VOC	CAS No.	CADR (m³/h)
Formaldehyde	50-00-0	71

Date: 27-December-2021

Report No.: 104675897GRR-001

P.O.: N/A

PHOTOGRAPHS:



Figure 3: Photograph of sample as tested in environmental testing chamber.

Date: 27-December-2021 P.O.: N/A

SECTION 4

FACILITIES AND EQUIPMENT:

HPLC	
INSTRUMENTATION USED:	Agilent 1260 Infinity Series
COLUMN USED:	Poroshell 120 EC-C18

Report No.: 104675897GRR-001